

Certificate



Aktiengesellschaft

No. z2364b-10-E

Customer:

SECOMP Electronic Components GmbH

Einsteinstraße 17-23

D-76275 Ettlingen

Test sample(s):

- Outlet:
ROLINE Cat.6 Surface Mount Box, shielded
Part No.: 25.16.8392 (white), 25.16.8393 (ivory)
- Panel:
ROLINE Cat.6 19" Patch Panel, 24 Ports, shielded
Part No.: 26.11.0361 (black), 26.11.0351 (light grey)
- Patchcord:
ROLINE Cat.6 S/FTP Patch Cord, 5m, grey
Part No.: 21.15.0835
- Data Cable:
ROLINE Cat.6 S/FTP Cable, Solid Wire, AWG23
Part No.: 21.15.0890 (100m), 21.15.0891 (300m)

Applied standard(s):

- ISO/IEC 11801 AMD 1 (2008-04)
- EN 50173-1 (2007-12)

Results:

Up to a bandwidth of **250 MHz** the sample meet the **Class E** limits of the specified standards and regulations.

Channel, Class E

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, **no. P2364b-10-E, from may 25th, 2010** and shall only be applicable in conjunction with the test report.

Bexbach, may 25th, 2010

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de